

Approval Number 260955034
Test Report: J-00558758 & RI0078/9/Ox



6th October 2026

Shandong Lvjia Air Conditioning Equipment Co., Ltd
Renheng Village,
Luquantun Town,
Wucheng County,
Dezhou City,
Shandong Province
China

Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

GLASS REINFORCED PLASTICS (GRP)- COMPONENTS.

5120

'Lvjia-GRP Water Tank Panel'. Grey coloured, hot press moulded GRP panel. For use with water up to 23°C.

APPROVAL NUMBER: 260955034

APPROVAL HOLDER: SHANDONG LVJIA AIR CONDITIONING EQUIPMENT CO., LTD

The Scheme reserves the right to review approval.

Approval 260955034 is valid between September 2026 and September 2031

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

Ian Hughes
WRAS Approvals Manager